

Asbestos Bulk Analysis Test Certificate



Hampshire Scientific Service
Asbestos Management Services Team
 Culture, Communities & Business Services
 Hyde Park Road, Southsea, Hampshire, PO5 4LL
 Telephone: 0370 779 0001
Director of Culture, Communities and Business Services
Felicity Roe



Client: Hampshire County Council **Surveyor Name:** Surveyor Name
Site: Site Name **Sampled By:** H-06146
 Address Line 1 **Project Ref:** P13305
 Address Line 2 **Your Ref:** 30 November 2022
 Postcode **Date Sampled/ Received:**

Analytical Procedure

Fibre identification was carried out in accordance with our method ASB-SOP-OM7 – Bulk Sample Analysis which is based on the HSE Publication HSG 248 Asbestos: The analysts guide for sampling, analysis and clearance procedures. Stereo microscopy, polarised light microscopy and dispersion staining techniques were employed

Results

Sample ID.	Sample Location	Product type	Size of sample analysed	Description of Sample		Asbestos Detected	Asbestos Type	Analyst	Date of Analysis
				General description e.g. colour, layering, homogeneity, location of asbestos fibres	Asbestos Type				
H-06146-01	Building 001X / XXXXXX Room 021, BOYS TOILET Above Ceiling, Item No. 2730889	Insulating Board	Sufficient	Grey, fibrous, homogenous	Yes	Amosite, Chrysotile	Analyst Name	01/12/2022	

NOTES:

- 1) Sample(s) were examined for the presence of 6 types of asbestos fibre: Crocidolite (blue), Amosite (brown), Chrysotile (white), Asbestos Anthophyllite, Asbestos Actinolite and Asbestos Tremolite.
- 2) Sample(s) collected by the client are evaluated using information provided by the client. For samples collected by the client the date of receipt is deemed to be the same as the date sampled.
- 3) Comments, observations, opinions, quantification of asbestos content in samples and sample description, are outside the scope of UKAS accreditation.
- 4) For ACMs in soils: only defined pieces of asbestos containing material (ACM) will be removed from the sample for analysis in accordance with HSG248. The sample description will be that of the ACM removed from the sample.

Analyst Name: Analyst Name **Checked and authorised by:** Lead Surveyor Name
Position: Senior Asbestos Surveyor **Position:** Asbestos Surveyor
Signed: Signature **Signed:** Signature
Date: 01/12/2022 **Date:** 01/12/2022