



NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES.
2. KERBS SHALL BE PRECAST CONCRETE KERBS COMPLYING WITH BS EN 1340.
WEATHERING RESISTANCE: CLASS 3
BENDING STRENGTH: CLASS 2
ABRASION RESISTANCE: CLASS 3.
SLIP/SKID RESISTANCE: MIN P.P.T.V. 45 TO BS 7932.
3. MIX ST1 CONCRETE KERB BEDDING TO CLAUSE 2602SR SHALL BE LAID ON SUBBASE AND SHALL BE A MINIMUM THICKNESS OF 150. SUBBASE SHALL BE EXCAVATED WHERE NECESSARY TO ACHIEVE 150 THICKNESS OF CONCRETE. RECOMPACT DISTURBED SUBBASE PRIOR TO CONSTRUCTION OF KERB BASE.
4. AS DESCRIBED IN CLAUSE 1101, SUB-CLAUSE 1, KERBS MAY BE LAID AND BEDDED ON MORTAR IN ACCORDANCE WITH CLAUSE 2601 OR LAID DIRECTLY ONTO THE CONCRETE BED. THE TYPE OF MORTAR SHALL BE APPROVED BY THE OVERSEEING ORGANISATION.
5. THE APPROPRIATE 914 LONG PRECAST CONCRETE TRANSITION KERB SHALL BE INSTALLED AT EACH CHANGE IN KERB TYPE, TIE-INS TO EXISTING AND AT TERMINATIONS.
6. UNLESS SPECIFIED ELSEWHERE FOR KERB TYPE PC4 (FLUSH), 125 x 150 x 914 CS2 SQUARE CHANNELS ARE TO BE USED.
7. THE MINIMUM LENGTH OF ANY CUT KERB SHALL BE 450.
8. THE KERB UPSTAND FOR TYPES PC1 AND PC2 SHALL BE 100 UNLESS OTHERWISE STATED, EXCEPT OVER BRIDGES WHERE IT SHALL BE AS SHOWN ON THE SCHEME DRAWINGS.

REV	AMENDMENTS	DATE	CAD	CHKD	APPD
-	-	-	-	-	-

CONSULTANT

Hampshire County Council Engineering CONSULTANCY

STUART JARVIS BSc DipTP FCIHT MRTPI: DIRECTOR OF ECONOMY, TRANSPORT & ENVIRONMENT

SCHEME

STANDARD DETAILS

DRAWING TITLE

PRECAST CONCRETE KERBS

HCC CADplot: 26.Nov.2015 at 1:29pm

DRAWN	CHECKED	SCALE @ A3
MC	WW, WW	N.T.S
CAD	APPROVED	DATE
MC	CP	July 2015
DRG No.	REVISION	
HCC10/C/010	-	

Copyright Hampshire County Council. 2015

All rights, including translation, reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopied, recorded or otherwise) without the prior written permission of Hampshire County Council. Requests should be directed to the Economy, Transport & Environment Department.