



16mm² GREEN INSULATED CONDUCTOR TO P.M.E. ELECTRODE. (THIS CABLE IS ONLY REQUIRED WHERE A P.M.E. ELECTRODE IS REQUIRED)

SINGLE PHASE DOUBLE POLE
TYPE NT06 LOOP IN/OUT
SINGLE FUSE

GENERAL CUT OUT WIRING SCHEMATIC
FOR COLUMNS AND ILLUMINATED SIGNS

NOTES:

1. THE CUT OUT SHALL BE MANUFACTURED FROM A SEMI-CRYSTALLINE THERMAL PLASTIC WITH IMPROVED HEAT RESISTANCE.
2. ALL SINGLE CORE WIRING SHALL BE TAPED TOGETHER EVERY METRE RUN.
3. THE WIRING IN THE BASE COMPARTMENT SHALL BE NEATLY CLEATED TO ONE SIDE OF THE BASE BOARD WITH SUFFICIENT TAIL LENGTH TO CONNECT INTO CUT OUT.
4. INSULATED CONNECTOR BLOCKS ARE TO BE PROVIDED IN THE BASE FOR TERMINATION OF THE CABLES BEING LOOPED.
5. ALL APPARATUS SHALL BE SECURELY FIXED AT ALL DESIGNATED POINTS TO A BACK BOARD OR HOUSING BY STAINLESS STEEL SCREWS. ALL EARTH CONNECTIONS SHALL BE BY BOLTED CRIMPED TERMINATIONS.

REV	AMENDMENTS	DATE	CAD	CHKD	APPD
-	-	-	-	-	-

CONSULTANT



 STUART JARVIS BSc DipTP FCIHT MRTPI: DIRECTOR OF ECONOMY, TRANSPORT & ENVIRONMENT

SCHEME

STANDARD DETAILS

DRAWING TITLE

TYPICAL BASE COMPARTMENT
ARRANGEMENT FOR COLUMNS OR
POSTS WITH SCOTTISH AND
SOUTHERN ENERGY PLC SERVICE

HCC CADplot: 10.Sep.2015 at 1:04pm						
DRAWN	WW	CHECKED	IH, IH	SCALE @ A3	N.T.S	
CAD	WW	APPROVED	CP	DATE	July 2015	
DRG No.	HCC10/L/080				REVISION	-

Copyright Hampshire County Council. 2015

All rights, including translation, reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopied, recorded or otherwise) without the prior written permission of Hampshire County Council. Requests should be directed to the Economy, Transport & Environment Department.