



CABLE GLAND TYPES CW & CX

NOTES:

1. THE WIRING IN THE BASE COMPARTMENT SHALL BE NEATLY CLEATED TO THE BASE BOARD WITH SUFFICIENT TAIL LENGTH TO CONNECT INTO CUT OUT.
2. ALL APPARATUS SHALL BE SECURELY FIXED TO THE BACK BOARD OR HOUSING BY STAINLESS STEEL SCREWS. ALL EARTH CONNECTIONS SHALL BE BY BOLTED CRIMPED TERMINATIONS.

| REV | AMENDMENTS | DATE | CAD | CHKD | APPD |
|-----|------------|------|-----|------|------|
| - | - | - | - | - | - |

CONSULTANT

STUART JARVIS BSc DipTP FCIBT MRTPI: DIRECTOR OF ECONOMY, TRANSPORT & ENVIRONMENT

SCHEME

STANDARD DETAILS

DRAWING TITLE

**STEEL WIRE ARMOUR CABLE
METHOD OF TERMINATION
FOR PRIVATE NETWORKS**

| | | | | | | |
|------------------------------------|-------------|----------|----|------------|-----------|---|
| HCC CADplot: 10.Sep.2015 at 1:04pm | | | | | | |
| DRAWN | WW | CHECKED | IH | SCALE @ A3 | N.T.S | |
| CAD | WW | APPROVED | CP | DATE | July 2015 | |
| DRG No. | HCC10/L/085 | | | | REVISION | - |

Copyright Hampshire County Council. 2015

All rights, including translation, reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopied, recorded or otherwise) without the prior written permission of Hampshire County Council. Requests should be directed to the Economy, Transport & Environment Department.