



CABLE GLAND TYPES CW & CX

NOTES

1. THE WIRING IN THE BASE COMPARTMENT SHALL BE NEATLY CLEATED TO THE BASE BOARD WITH SUFFICIENT TAIL LENGTH TO CONNECT INTO CUT OUT.
2. ALL APPARATUS SHALL BE SECURELY FIXED TO THE BACK BOARD OR HOUSING BY STAINLESS STEEL SCREWS. ALL EARTH CONNECTIONS SHALL BE BY BOLTED CRIMPED TERMINATIONS.



A	BRANDING UPDATED	15.07.2022	CLT	CLT	APPD
REV	AMENDMENTS	DATE	CAD	CHKD	APPD

CONSULTANT



**Hampshire
County Council**



**Hampshire
Engineering
Services**

STUART JARVIS BSc DipTP FCIHT MRTPI: DIRECTOR OF ECONOMY, TRANSPORT & ENVIRONMENT

SCHEME

STANDARD DETAILS

DRAWING TITLE

**STEEL WIRE ARMOUR CABLE
METHOD OF TERMINATION
FOR PRIVATE NETWORKS**

DESIGNER	WW	CHECKED	IH IH	SCALE @ A3	N.T.S
CAD	WW	APPROVED	JH JH	DATE	March 2020
DRAWING NUMBER	HCC11/L/065			REV	A

Copyright Hampshire County Council. 2022

All rights, including translation, reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopied, recorded or otherwise) without the prior written permission of Hampshire County Council. Requests should be directed to the Economy, Transport & Environment Department.