


CABLE GLAND TYPES CW & CX

NOTES

1. THE WIRING IN THE BASE COMPARTMENT SHALL BE NEATLY CLEATED TO THE BASE BOARD WITH SUFFICIENT TAIL LENGTH TO CONNECT INTO CUT OUT.
2. ALL APPARATUS SHALL BE SECURELY FIXED TO THE BACK BOARD OR HOUSING BY STAINLESS STEEL SCREWS. ALL EARTH CONNECTIONS SHALL BE BY BOLTED CRIMPED TERMINATIONS.



B	COPYRIGHT AMENDED AND NEW DIRECTORATE DETAILED.	06.02.2023	AM	SCC	J
A	BRANDING UPDATED.	15.07.2022	CLT	IH	JH
REV	AMENDMENTS	DATE	CAD	CHKD	APPD

CONSULTANT

Hampshire County Council

Hampshire Engineering Services

TIM LAWTON BEng CEng FICE FCIHT : ASSISTANT DIRECTOR OF UNIVERSAL SERVICES

SCHEME

STANDARD DETAILS

DRAWING TITLE

STEEL WIRE ARMOUR CABLE
METHOD OF TERMINATION
FOR PRIVATE NETWORKS

DESIGNER	CHECKED	SCALE @ A3
WW	IH IH	N.T.S
CAD	APPROVED	DATE
WW	JH JH	March 2020
DRAWING NUMBER	REV	
HCC11/L/065	B	

Copyright Hampshire County Council.

All rights, including translation, reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopied, recorded or otherwise) without the prior written permission of Hampshire County Council. Requests should be directed to Hampshire Engineering Services.