



NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES.
2. ALL DUCTING AND CABLES SHALL BE LAID IN ACCORDANCE WITH THE CURRENT EDITION OF NJUG IN CONJUNCTION WITH THE CURRENT EDITION OF HAUC (UK).
3. WITHIN TRAFFIC ISLANDS THE MINIMUM COVER SHALL BE 150.
4. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH SPECIFICATION CLAUSE 1421 OF THE SPECIFICATION FOR HIGHWAY WORKS.
5. FOR LOCATION OF CABLES AND DUCTS SEE STREET LIGHTING LAYOUT DRAWINGS.
6. DUCT DIA. 100/150 FOR ROAD CROSSINGS AND 75/100 WITHIN TRAFFIC ISLANDS.
7. WHERE CABLE COVERS ARE SPECIFIED IN APPENDIX 14/4 THE COVER SIZE SHALL BE 150x225 FOR A SINGLE CABLE NOT EXCEEDING 50 DIAMETER AND 225x300 FOR A SINGLE CABLE EXCEEDING 50 DIAMETER OR TWO CABLES NOT EXCEEDING 37 DIAMETER EACH.
8. CABLES SHALL HAVE MINIMUM CLEARANCE OF 500 TO SAFETY POST FOUNDATION.

REV	AMENDMENTS	DATE	CAD	CHKD	APPD

CONSULTANT

STUART JARVIS BSc DipTP FCIHT MRTPI: DIRECTOR OF ECONOMY, TRANSPORT & ENVIRONMENT

SCHEME

STANDARD DETAILS

DRAWING TITLE

UNDERGROUND CABLING FOR PRIVATE CABLE NETWORKS

HCC CADplot: 25.Feb.2020 at 9:32pm		SCALE @ A3
DRAWN	CHECKED	SCALE @ A3
WW	IH, IH	N.T.S
CAD	APPROVED	DATE
WW	JH, JH	March 2020
DRG No.	REVISION	
HCC11/L/050		

Copyright Hampshire County Council. 2019

All rights, including translation, reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopied, recorded or otherwise) without the prior written permission of Hampshire County Council. Requests should be directed to the Economy, Transport & Environment Department.

Use only in conjunction with the current edition of the Standard Details (Scheme) as indicated. Dec 2011 HCC11 0000 STANDARD DETAILS (Scheme) 050.dwg