



CABLE GLAND TYPES CW & CX

NOTES:

1. THE WIRING IN THE BASE COMPARTMENT SHALL BE NEATLY CLEATED TO THE BASE BOARD WITH SUFFICIENT TAIL LENGTH TO CONNECT INTO CUT OUT.
2. ALL APPARATUS SHALL BE SECURELY FIXED TO THE BACK BOARD OR HOUSING BY STAINLESS STEEL SCREWS. ALL EARTH CONNECTIONS SHALL BE BY BOLTED CRIMPED TERMINATIONS.

REV	AMENDMENTS	DATE	CAD	CHKD	APPD

CONSULTANT



STUART JARVIS BSc DipTP FCIHT MRTPI: DIRECTOR OF ECONOMY, TRANSPORT & ENVIRONMENT

SCHEME

STANDARD DETAILS

DRAWING TITLE

**STEEL WIRE ARMOUR CABLE
METHOD OF TERMINATION
FOR PRIVATE NETWORKS**

<small>HCC CADplot: 25.Feb.2020 at 9:34pm</small>		
DRAWN	CHECKED	SCALE @ A3
WW	IH , IH	N.T.S
CAD	APPROVED	DATE
WW	JH , JH	March 2020
DRG No.	REVISION	
HCC11/L/065		

Copyright Hampshire County Council. 2019

All rights, including translation, reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopied, recorded or otherwise) without the prior written permission of Hampshire County Council. Requests should be directed to the Economy, Transport & Environment Department.

I:\Projects\2019\HCC11\0000 STANDARD DETAILS\1 - Details - 065.dwg