



SECTION A-A

Copyright Hampshire County Council. 2015

All rights, including translation, reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopied, recorded or otherwise) without the prior written permission of Hampshire County Council. Requests should be directed to the Economy, Transport & Environment Department.

NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES.
2. GRANITE SETTS ARE TO BE 100 x 100 x 200 DEEP, SILVER GREY IN COLOUR, WITH A ROUGH HEWN FINISH. THEY SHALL HAVE A MINIMUM POLISHED PENDULUM TEST VALUE (PTV), EQUIVALENT TO THE PSV OF AGGREGATE IN ACCORDANCE WITH HD36/06 AND THE PSV OF AGGREGATE USED IN THE ADJACENT CARRIAGEWAY SURFACING, WITH A MAXIMUM ABRASION RESISTANCE OF 18 (WIDE WHEEL ABRASION). THE MINIMUM SIZE OF CUT SETT SHALL BE 1/2 THE NORMAL SIZE.
3. CONSTRUCT TABLE EDGES IN 145 x 145 x 300 LONG SILVER GREY 'CONSERVATION' CHANNELS BEDDED IN ST4 CONCRETE MIX. CHANNELS SHALL BE FORMED WITH 8 WIDE JOINTS FILLED WITH 1:1.5 CEMENT/SAND MORTAR (PROPORTIONS BY VOLUME) CONTAINING SAND COMPLYING WITH BS EN 13139 0/4 MP FINE AGGREGATE FINES CATEGORY 1. CHANNELS TO BE LAID TO FOLLOW GENERALLY THE CROSS SECTIONAL PROFILE OF THE ROAD IN A FLOWING ALIGNMENT.
4. JOINTS BETWEEN GRANITE SETTS SHALL BE FILLED FULL DEPTH WITH GREY 'EASIPPOINT' MORTAR AS MANUFACTURED BY EASIPOINT MARKETING LTD, OR EQUIVALENT, APPLIED BY GUN INJECTION SYSTEM. BUCKET HANDLE FINISH.
5. CARRIAGEWAY CONSTRUCTION AND ANY SUB-BASE FOUNDATION TO RUMBLE STRIP AS SCHEME SPECIFIC DRAWINGS. SUBBASE SHALL BE TO CLAUSE 803 OR CLAUSE 891AR, 892AR, 893AR OR 894AR QH.

REV	AMENDMENTS	DATE	CAD	CHKD	APPD
-	-	-	-	-	-

CONSULTANT

Hampshire County Council **Engineering CONSULTANCY**

STUART JARVIS BSc DipTP FCIHT MRTPI: DIRECTOR OF ECONOMY, TRANSPORT & ENVIRONMENT

SCHEME

STANDARD DETAILS

DRAWING TITLE

RUMBLE STRIP

HCC CADplot: 18.Sep.2015 at 2:14pm

DRAWN	RB	CHECKED	WW, WW	SCALE @ A3	N.T.S
CAD	RB	APPROVED	CP	DATE	July 2015
DRG No.	HCC10/M/040			REVISION	-