



- NOTES**
- ALL DIMENSIONS IN MILLIMETRES
 - LEGEND**
 - PROPOSED OVERLAY
 - SURFACE COURSE MATERIAL AS DETAILED IN APPENDIX 7/1.
 - BINDER/BASE MATERIAL AS DETAILED IN APPENDIX 7/1.
 - SUBBASE SHALL BE TO CLAUSE 803, OR WITH OVERSEEING ORGANISATION APPROVAL, TO CL. 807, CL. 822 OR, WHERE PERMITTED, CL. 893AR AS DETAILED IN APPENDIX 7/1.
 - THE WIDTH OF CUT BACK SHALL BE AS SPECIFIED IN APPENDIX 7/2.
 - SAW CUT AROUND THE AREA TO BE RECONSTRUCTED TO AT LEAST THE DEPTH OF SURFACE COURSE LAYER.
 - TREATMENT OF LAYERS AND VERTICAL SURFACES SHALL BE IN ACCORDANCE WITH CL. 903. BOND COAT SHALL BE SPECIFIED IN APPENDIX 7/4 AND SHALL BE APPLIED TO EACH BITUMINOUS SURFACE.
 - UNLESS OTHERWISE STATED IN APPENDIX 7/2, FOR REPAIR TYPES A4 AND B4 A GLASS FIBRE COMPOSITE PAVEMENT REINFORCEMENT GRID TYPE 1 AS DETAILED WITHIN APPENDIX 7/1 SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS BENEATH THE BINDER LAYER SPANNING THE EDGE OF THE REPAIR BY 500mm EITHER SIDE.
 - CBGM TO CL. 822 SHALL BE C8/10 WITH REFERENCE TO BS 9227.

Copyright Hampshire County Council.

All rights, including translation, reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopied, recorded or otherwise) without the prior written permission of Hampshire County Council. Requests should be directed to Hampshire Engineering Services.

B	COPYRIGHT AMENDED AND NEW DIRECTORATE DETAILED	10.02.2023	AM	PR	
A	SUBBASE TO CL. 893AR DELETED, CL. 822 ADDED, NOTES ADDED AND AMENDED AND BRANDING UPDATED	18.07.2022	CLT	FR	SDG
REV	AMENDMENTS	DATE	CAD	CHKD	APPD

CONSULTANT

TIM LAWTON BEng CEng FICE FCIHT : ASSISTANT DIRECTOR OF UNIVERSAL SERVICES

SCHEME

STANDARD DETAILS

DRAWING TITLE

CARRIAGEWAY REPAIR DETAILS

DESIGNER	CHECKED	SCALE @ A3
MC	AH AH	N.T.S
CAD	APPROVED	DATE
MC	SDG SDG	March 2020
DRAWING NUMBER	REV	
HCC11/M/030	B	