



FOOTWAY TYPE 1 - FLEXIBLE CONSTRUCTION

NOTES

- ALL DIMENSIONS ARE IN MILLIMETRES.
- ALSO REFER TO APPENDIX 11/1.
- PRECAST CONCRETE EDGINGS SHALL BE 150 x 50 TYPE EF TO BS EN 1340 REQUIRED AS EDGE RESTRAINT TO BACK OF FOOTWAY AND ADJOINING VERGE: -
WEATHERING RESISTANCE: CLASS 3
BENDING STRENGTH: CLASS 2
ABRATION RESISTANCE: CLASS 3.
SLIP/SKID RESISTANCE: MIN P.P.T.V. 45.
- SUBBASE SHALL BE TO CLAUSE 803, OR WITH OVERSEEING ORGANISATION APPROVAL, TO CL. 807, CL. 822, OR, WHERE PERMITTED, TO CL. 893AR, AS SPECIFIED IN THE WORKS INFORMATION.
- PCC EDGINGS SHALL BE INSTALLED IN ACCORDANCE WITH DRAWING HCC11/C/045.
- STANDARD DETAILS OF KERBS, BED AND BACKING ARE ON DRAWING HCC11/C/010 TO 30. PROPOSED KERB TYPE SHOULD MATCH EXISTING.
- THE GRADIENT OF THE DROPPED CROSSING SHALL BE 1 IN 12 MAXIMUM, BUT THE OVERSEEING ORGANISATION WILL DETERMINE THE PRECISE LOCATION AND GRADIENT ON SITE PRIOR TO CONSTRUCTION AND THE EXTENT OF ANY FLAT AREA AT THE REAR OF THE FOOTWAY AS THIS WILL BE DEPENDANT ON THE SITE SPECIFIC GRADIENTS/DIMENSIONS.
- 4 No. DROPPED KERBS SHALL BE PROVIDED UNLESS SITE SPECIFIC CONDITIONS PREVENT THIS. A MINIMUM OF 3 No. DROPPED KERBS MAY BE USED WITH THE AGREEMENT OF THE OVERSEEING ORGANISATION.
- ANY EXCAVATION AND REINSTATEMENT IN FRONT OF THE NEW KERB SHALL BE DETERMINED BY THE OVERSEEING ORGANISATION.
- TREATMENT OF LAYERS AND VERTICAL SURFACES SHALL BE IN ACCORDANCE WITH CL. 903. BOND COAT SHALL BE SPECIFIED IN APPENDIX 7/4.
- CRBM TO CL. 948 SHALL BE QVE, B4 WITH REFERENCE TO BS 9228.
- CBGM TO CL. 822 SHALL BE C5/6 WITH REFERENCE TO BS 9227.

B	COPYRIGHT AMENDED AND NEW DIRECTORATE DETAILED	10.02.2023	AM	PR	
A	CROSSFALLS, BINDER AND SUBBASE DETAILS AMENDED, NOTES ADDED AND AMENDED AND BRANDING UPDATED	18.07.2022	CLT	PR	SDG
REV	AMENDMENTS	DATE	CAD	CHKD	APPD

CONSULTANT

TIM LAWTON BEng CEng FICE FCIHT : ASSISTANT DIRECTOR OF UNIVERSAL SERVICES

STANDARD DETAILS

TYPICAL VEHICLE CROSSING IN EXISTING FOOTWAY

DESIGNER	CHECKED	SCALE @ A3
MC	AH AH	N.T.S
CAD	APPROVED	DATE
MC	SGD SGD	March 2020
DRAWING NUMBER	REV	
HCC11/M/040	B	

Copyright Hampshire County Council.
All rights, including translation, reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopied, recorded or otherwise) without the prior written permission of Hampshire County Council. Requests should be directed to Hampshire Engineering Services.

